

GRITS 11/17/2021

H.013710 I-10: US-61 to Laplace ITS Deployment

Creating ITS Infrastructure in Rural Louisiana



Agenda


Balleres .

-

- 1. Safety Moment
- 2. Background
- 3. Project Description
- 4. Solar Site Design
- 5. Conclusion

Safety Moment

Stantec follows ISO 9001 certified field safety practices on all projects





(D) GATHERING (D)






Background

Rural Infrastructure Needs

2045

C an




Louisiana ITS Coverage


Focused on large cities

• Fiber network is extensive, but device locations limited by power in some areas

Mississippi ITS Coverage


Bator





Alabama ITS Coverage

H.013710 Project Description



System Goals

- Eliminate crashes and increase safety of transportation system
- Rapid detection
- Rapid verification
- Dispatch emergency services
 and MAP
- **ZERS** DEATHS
- Communicate with Motorists




Objectives



Connect Existing Hub site at US-61 to Existing Radio Tower in Laplace via 96 strand SMFO

Connect existing CCTV and DMS sites to new Fiber

Install additional 7 CCTV sites, 4 solar-powered



Utility Costs (Estimated)



Utility Costs (Estimated)

Choosing and Sizing Solar Components

Loads:


1 Cohu camera

2 cabinet fans

1 cabinet light

Ruggedcom switch

66 Ah per day



Choosing and Sizing Solar Components

Battery – Gel Lead Acid, sized based on IEEE Std. 1013-2019 (Worksheet 1) – 6 standard 24 VDC batteries, 7.56 kWh capacity


Solar Array – sized based on IEEE St. 1562-2007 (Worksheet 1) – 4 PV modules providing 24 VDC and 9.2 A

Choosing and Sizing Solar Components

Solar Cables – sized per NEC 690.8 (A) (1)


Solar OCPD – sized per NEC 690.0 (B)

Arc Fault Protection not required due to voltage (required for systems 80VDC and higher)



Note: NFPA 855-20 "Installation of Stationary Energy Storage Systems" may apply to the site design. The standard does not apply to lead-acid battery installations less than 70 kWh storage capacity. MUTCD latest edition and NESC may have applicable standards as well depending upon the site location.

Fiber Backbone Design



Solar Costs

Engineer's Estimate	Contractor's Bid (8 total)
Solar Power System - \$122,500	Solar Power System - \$60,000 (winning bid), \$105,000 (average bid)
Clearing and Grubbing - \$5,000	Clearing and Grubbing - \$3,250 (winning bid), \$8,750 (average bid)
Total for 4 - \$510,000	Total for 4: \$253,000 (winning bid)
Total Project Estimate - \$4.5M	Total Project Bid - \$4M

Estimated Utility costs totaled at least \$1.04M

No additional TTC, ROW, or Permits required

Conclusion



INITIAL COST SAVINGS

RELIABILITY

MAINTENANCE



Without change there is no innovation, creativity, or incentive for improvement. Those who initiate change will have a better opportunity to manage the change that is inevitable.

William Pollard

